

Nexans Ref. Code	Formation	Nominal Conductor Diameter	Minimum Insulation Thickness	Nominal Insulation Diameter	Nominal Sheaths Thickness	Nominal Cable Diameter	Indicative Cable Weight
		[mm]	[mm]	[mm]	[mm]	[mm]	[kg/km]
-	1x50	8,2	7,1	24,7	2,0+2,0	37,5	1.050
-	1x70	9,8	7,1	25,8	2,0+2,0	38,6	1.145
10557490	1x95	11,5	6,6	26,5	2,0+2,0	39,4	1.225
-	1x120	13,1	6,4	27,7	2,0+2,0	40,6	1.335
10541200	1x150	14,3	6,2	28,5	2,0+2,0	41,5	1.430
10540849	1x185	16,0	6,0	29,8	2,0+2,0	42,8	1.565
10544978	1x240	18,5	5,8	31,9	2,0+2,0	45,0	1.790
10545009	1x300	20,7	5,9	34,3	2,0+2,0	47,6	2.035
10540880	1x400	23,5	6,0	37,3	2,0+2,0	50,7	2.375
10540881	1x500	26,5	6,1	40,8	2,0+2,0	54,4	2.820
10549363	1x630	30,0	6,2	44,5	2,0+2,0	58,3	3.360