

Nexans Ref. Code	Formation	Nominal Conductor Diameter	Nominal Insulation Thickness	Nominal Insulation Diameter	Nominal Sheaths Thickness	Nominal Cable Diameter	Indicative Cable Weight
		[mm]	[mm]	[mm]	[mm]	[mm]	[kg/km]
-	1x150	14,3	7,0	28,5	2,0+2,0	41,5	1.405
-	1x185	16,0	6,8	29,8	2,0+2,0	42,8	1.535
-	1x240	18,5	6,8	32,3	2,0+2,0	45,5	1.790
-	1x300	20,7	6,8	34,5	2,0+2,0	47,8	2.020
10564706	1x400	23,5	6,8	37,3	2,0+2,0	50,7	2.345
10568171	1x500	26,5	6,9	40,8	2,0+2,0	54,4	2.795
-	1x630	30,0	7,0	44,5	2,0+2,0	58,3	3.320