

<i>Nexans Ref. Code</i>	<i>Formation</i>	<i>Nominal Conductor Diameter</i>	<i>Nominal Insulation Thickness</i>	<i>Nominal Insulation Diameter</i>	<i>Nominal Sheath Thickness</i>	<i>Nominal Cable Diameter</i>	<i>Indicative Cable Weight</i>
		[mm]	[mm]	[mm]	[mm]	[mm]	[kg/km]
-	<b>1x150</b>	14,3	7,0	28,5	4,0	41,5	1.405
-	<b>1x185</b>	16,0	6,8	29,8	4,0	42,8	1.535
-	<b>1x240</b>	18,5	6,8	32,3	4,0	45,5	1.790
-	<b>1x300</b>	20,7	6,8	34,5	4,0	47,8	2.020
-	<b>1x400</b>	23,5	6,8	37,3	4,0	50,7	2.345
-	<b>1x500</b>	26,5	6,9	40,8	4,0	54,4	2.795
-	<b>1x630</b>	30,0	7,0	44,5	4,0	58,3	3.320