

Nexans Ref. Code	Formation	Nominal Conductor Diameter	Nominal Insulation Thickness	Nominal Insulation Diameter	Nominal Sheaths Thickness	Nominal Phase Diameter	Nominal Cable Diameter	Indicative Cable Weight
		[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[kg/km]
-	3x1x95	11,5	4,9	21,9	2,0+2,0	34,5	74,4	2.910
-	3x1x120	13,1	4,9	23,5	2,0+2,0	36,2	78,0	3.270
-	3x1x150	14,3	4,9	24,7	2,0+2,0	37,5	80,7	3.600
-	3x1x185	16,0	4,9	26,4	2,0+2,0	39,3	84,6	4.050
-	3x1x240	18,5	4,9	28,9	2,0+2,0	41,9	90,3	4.760
-	3x1x300	20,7	4,9	31,1	2,0+2,0	44,2	95,2	5.430
-	3x1x400	23,5	4,9	33,9	2,0+2,0	47,1	101,6	6.360
-	3x1x500	26,5	4,9	37,2	2,0+2,0	50,6	109,1	7.590