

Nexans Ref. Code	Formation	Nominal Conductor Diameter	Nominal Insulation Thickness	Nominal Insulation Diameter	Nominal Sheaths Thickness	Nominal Phase Diameter	Nominal Cable Diameter	Indicative Cable Weight
		[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[kg/km]
-	3x1x150	14,3	7,0	28,5	2,0+2,0	41,5	89,4	4.230
-	3x1x185	16,0	6,8	29,8	2,0+2,0	42,8	92,3	4.620
-	3x1x240	18,5	6,8	32,3	2,0+2,0	45,5	98,0	5.370
-	3x1x300	20,7	6,8	34,5	2,0+2,0	47,8	103,0	6.070
-	3x1x400	23,5	6,8	37,3	2,0+2,0	50,7	109,3	7.040