

Nexans Ref. Code		10562759	10562800
Formation		3x1x185	3x1x240
Nominal Conductor Diameter	[mm]	16,0	18,5
Minimum Insulation Thickness	[mm]	4,31	4,31
Nominal Insulation Diameter	[mm]	26,4	28,9
Aluminum tape Nominal Section	[mm ²]	30,0	33,0
Nominal Sheath Thickness	[mm]	2,75	3,0
Nominal Phase Diameter	[mm]	35,5	38,5
Nominal Cable Diameter	[mm]	76,4	83,1
Indicative Cable Weight	[kg/km]	3.690	4.470